

**DIVISION 9 - SECTION 09 60 00.11**  
**ISOLayment QT-B Re-bonded Recycled Rubber Impact**  
**Sound Underlayment**

**PART 1.0- GENERAL**

1.1 SUMMARY

A. Work includes:

1. Types of re-bonded recycled rubber impact sound underlayment.
2. Adhesives

B. Related Sections:

1. Concrete Substrate
2. Plywood Substrate
3. Tile
4. Carpeting
5. Noise Control and Vibration Isolation

1.2 REFERENCES

A. Standards listed by reference, including revisions by issuing authority, form a part of this specification section to extent indicated. Standards listed are identified by issuing authority, authority abbreviation, designation number, title, or other designation established by issuing authority. Standards subsequently referenced herein are referred to by issuing authority abbreviation and standard designation.

B. American Society for Testing and Materials (ASTM):

1. ASTM E492 Standard Test Method for Laboratory Measurement of Impact Sound Transmission Through Floor-Ceiling Assemblies Using the Tapping Machine.
2. ASTM C627 Standard Test Method for Evaluating Ceramic Floor Tile Installation Systems Using the Robinson-Type Floor Tester.

ISOLayment QT-B

3. ASTM E989 Standard Classification for Determination of Impact Insulation Class (IIC)
  4. ASTM E1007 Standard Test Method for Field Measurement of Tapping Machine Impact Sound Transmission Through Floor-Ceiling Assemblies and Associated Support Structures.
  5. ASTM E2179 Standard Test Method for Laboratory Measurement of the Effectiveness of Floor Coverings in Reducing Impact Sound Transmission Through Concrete Floors.
  6. ASTM E90 Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements.
  7. ASTM F2170 Standard Test Method for Determining Relative Humidity in Concrete Floor Slabs Using in situ Probes.
  8. ASTM D5116 CHPS/CA 01350 – Collaborative of High Performance Schools, Low-Emitting Materials Criteria.
  9. ASTM E336 Standard Test Method for Measurement of Airborne Sound Insulation in Buildings
- C. South Coast Air Quality Management District (SCAQMD) Rule #1168
1. VOC standards for adhesive and sealant applications
- D. Leadership in Energy and Environmental Design – LEED®
1. International Organization for Standardization® document, ISO 14021 – Provides guidance on the terminology, symbols, testing, and verification methodologies that an organization should use for self-declaration of the environmental aspects of its products and services.

### 1.3 SYSTEM DESCRIPTION

- A. Performance Requirements: Provide recycled rubber resilient flooring, which has been manufactured and installed to maintain performance criteria stated by manufacturer without defects, damage, or failure.

### 1.4 SUBMITTALS

- A. General: Submit listed submittals in accordance with Conditions of the Contract and Division 1 Submittal Procedures Section.
- B. LEED: Provide documentation of how the requirements for credit will be met.

ISOLayment QT-B

1. List of proposed materials with recycled content. Indicate pre-consumer and post-consumer content.
2. Product data and certification letter indicating percentage of recycled content for both pre-consumer and post-consumer content.
3. Recycled content is defined in accordance with the International Organization for Standardization document, ISO 14021 Environmental labels and declarations.
  - a. Post-consumer material - waste materials diverted from the waste stream after consumer or commercial use.
  - b. Pre-consumer material - materials diverted from the waste stream during the manufacturing process. Excluded are regrind, rework, and scrap.
- C. Product Data: Submit product data, including manufacturer's guide specifications product sheet, for specified products.
- D. Shop Drawings: Manufacturer's specifications, catalog cuts, and other items needed to demonstrate compliance with the specified requirements. Also the manufacturer's recommended installation procedures, which, when approved by the architect, will become the basis for accepting or rejecting actual installation procedures used on the work.
- E. Samples: Submit selection and verification samples for finishes, colors, and textures.
- F. Quality Assurance Submittals: Submit the following:
  1. Certificates: If required, certification of performance characteristics specified in this document shall be provided by the manufacturer.
  2. Manufacturer's Instructions: Manufacturer's installation instructions.
- G. Closeout Submittals:
  1. Warranty.

## 1.5 QUALITY ASSURANCE

- A. Qualifications:
  1. Installer Qualifications: Installer experienced in performing work of this section who has specialized in installation of work similar to that required for this project.
    - a. Certificate: When requested, submit certificate indicating qualification.
  2. Manufacturer's Qualifications: Manufacturer capable of approving application method.

*ISOL*ayment QT-B

- B. Regulatory Requirements: [specify applicable requirements of regulatory agencies].
- C. Mock-Ups: Install at project site a job mock-up using acceptable products and manufacturer-approved installation methods. Comply with workmanship standard. Comply with Division 1 Quality Control (Mock-Up Requirements) Section.
  - 1. Mock-Up Size: As determined by acoustical consultant.
  - 2. Maintenance: Maintain mock-up during construction for workmanship comparison; remove and legally dispose of mock-up when no longer required.
  - 3. Incorporation: Mock-up may be incorporated into final construction upon Owner's approval.
- D. Pre-Installation Meetings: Conduct pre-installation meeting to verify project requirements, substrate conditions, manufacturer's instructions, and manufacturer's warranty requirements. Comply with Division 1 Project Management and Coordination (Project Meetings) Section.
- E. Pre-Installation Testing: Conduct pre-installation testing as follows: [specify substrate testing; consult with flooring manufacturer].

#### 1.6 DELIVERY, STORAGE & HANDLING

- A. General: Comply with Division 1 Product Requirements Sections.
- B. Ordering: Comply with manufacturer's ordering instructions and lead time requirements to avoid construction delays.
- C. Delivery: Deliver materials in manufacturer's original, unopened, undamaged containers with identification labels intact.
- D. Storage and Protection: Store materials at temperature and humidity conditions recommended by manufacturer and protect from exposure to harmful weather conditions.

#### 1.7 PROJECT CONDITIONS

- A. Temperature Requirements: Maintain air temperature in spaces where products will be installed for time period before, during, and after installation as recommended by manufacturer.
- B. Field Measurements: Verify actual measurements/openings by field measurements before fabrication; show recorded measurements on shop drawings. Coordinate field measurements and fabrication schedule with construction progress to avoid construction delays.

#### 1.8 WARRANTY

- A. Project Warranty: Refer to Conditions of the Contract for project warranty provisions.

*ISOL*ayment QT-B

1. The recommendations for applications and installation are based on our extensive experience and on current technological practice. Our liability and responsibility in the event of damages is limited to the extent defined in our General Terms and Conditions of Business and is not in any way increased by the above recommendations or by advice given by our sales representatives or applications engineering staff.

## 1.9 MAINTENANCE

- A. Extra Materials: Deliver to Owner extra materials from same production run as products installed. Package products with protective covering and identify with descriptive labels. Comply with Division 1 Closeout Submittals (Maintenance Materials) Section.

1. Quantity: Furnish quantity of re-bonded recycled rubber Impact Sound Isolation units as requested on purchase order.
2. Delivery, Storage, and Protection: Comply with Owner's requirements for delivery, storage, and protection of extra materials.

## PART 2.0 - PROPRIETARY SUPPLIER/PRODUCTS

### 2.1 SUPPLIER: Kinetics Noise Control, Inc. (Kinetics)

- A. Address: 6300 Irelan Place, Dublin, OH 43017; Telephone: (614) 889-0480, (877) 457-2695; Fax: (614) 889-0540; Email: archsales@kineticsnoise.com Represented by KPA Architectural Products in New England – Contact Keith Peterson (508) 591-7500

### 2.2 PROPRIETARY PRODUCT(S)

- A. *ISOL*ayment QT-B Re-bonded Recycled Rubber Impact Sound Underlayment and Adhesives

1. *ISOL*ayment QT-B Re-bonded Recycled Rubber Underlayment
2. *ISOL*ayment QT Polyethylene Foam Perimeter Isolation Strip
3. One-component polyurethane adhesive

#### 2.3.1 *ISOL*ayment QT-B Re-bonded Recycled Rubber Impact Sound Isolation Underlayment

- A. Product Name: The non-laminated, single-ply re-bonded rubber underlayment furnished under this specification shall be Kinetics *ISOL*ayment QT-B Re-bonded Recycled Rubber Impact Sound Isolation Underlayment.
- B. Material: Made from 92% recycled SBR (Styrene-Butadiene Rubber) tire rubber. *ISOL*ayment QT-B is a dimpled, resilient base mat that can be applied under gypsum or full weight concrete to produce

*ISOL*ayment QT-B

some of the thinnest sound rated systems in the industry.

- C. Dimension: *ISOL*ayment QT-B rolled rubber underlayment will have an overall thickness of (specify: 1/4" [6 mm] standard in 4.5' by 30' [1.4 m by 9.1 m] roll size or 3/8" [10 mm] standard in 4.5' by 30' [1.4 m by 9.1 m] roll size or 3/4" [17 mm] standard in 4.5' by 30' [1.4 m by 9.1 m] roll size) or 1" [25 mm] standard in 4' by 30' [1.2 m by 9.1 m] roll size).
- D. Weight: 0.6 lb/ft<sup>2</sup> [2.8 kg/m<sup>2</sup>], 1.0 lb/ft<sup>2</sup> [5.1 kg/m<sup>2</sup>], 1.3 lb/ft<sup>2</sup> [6.3 kg/m<sup>2</sup>], 1.6 lb/ft<sup>2</sup> [7.9 kg/m<sup>2</sup>]
- E. Standard Tolerances: Roll width: +3/4" - 0", Roll length: + 1% - 0", Thickness: ± 0.3 mm
- F. Impact Insulation Class Laboratory (ASTM E492): Specified floor-ceiling assembly must be tested in a NVLAP certified laboratory and comply with ASTM standards.
- G. Impact Insulation Class Field (ASTM E1007): Floor-ceiling assembly must meet requirement as stated by building code and/or acoustical consultant.
- H. Shall be ICC-ES certified
- I. Shall be UL listed
- J. VOC Washington State IAQ Test (ASTM D5116): pass

### 2.3.2 *ISOL*ayment QT Polyethylene Foam Perimeter Isolation Strip

- A. Product Name: The single-ply white polyethylene foam perimeter isolation strip under this specification shall be Kinetics QT Polyethylene Foam Perimeter Isolation Strip.
- B. Material: Made from white polyethylene foam, *ISOL*ayment QT Perimeter Isolation Strip is a flat, resilient strip that is used to build a tub around the floor so that no hard surface (floor covering) touches any hard vertical surface (protrusion or wall).
- C. Dimension: *ISOL*ayment QT rolled perimeter isolation strip will have an overall thickness of 15/64" [6mm] in 2 1/2" by 50' [64mm by 1,5240mm] roll size
- D. Weight: 0.035 lb/ft<sup>2</sup> [0.171 kg/m<sup>2</sup>]

### 2.3.3 One-component polyurethane adhesive

- A. The one-part urethane adhesive under this specification shall be a Kinetics-supplied, one-component polyurethane adhesive.
- B. Material: A one-component polyurethane moisture cured, non-sag, permanently elastic adhesive that has excellent adhesion to elastomers, concrete, and wood and is engineered for indoor and outdoor applications.

*ISOL*ayment QT-B

- C. Adhesive Type: one-component polyurethane
  - D. Adhesive Cure System: moisture cured
  - E. Weight: 4 gallon pail - 56 lbs.
  - F. Color: medium grey
  - G. VOC Content: 0 Calculated
  - H. Freeze/Thaw: stable
  - I. Application Temperature: 40° F - 100° F
  - J. Relative Humidity Test (ASTM F2170): Maximum 75%
  - K. Calcium Chloride Test (ASTM F1869): Maximum 5.5 lbs./1,000 sq. ft. in 24 hrs.
  - L. Flashpoint: > 500° F
  - M. Shelf Life: 12 months
  - N. Working Time: 30-40 minutes
  - O. Trowel: 1/16" square notched trowel <sup>(1)</sup>
  - P. Coverage Rate: 95 ft<sup>2</sup> per gallon (1/16" square notched trowel) Q.
- SCAQMD Rule #1168: 0 Calculated

(1) For indoor installation on concrete or plywood subfloors only. See *ISOL*ayment QT Installation Manual for instructions.

## 2.4 PRODUCT SUBSTITUTIONS

- A. Substitutions: No substitutions permitted.

## 2.5 RELATED MATERIALS

- A. Related Materials: Refer to other sections listed in Related Sections paragraph herein for related materials.

## 2.6 SOURCE QUALITY

*ISOL*ayment QT-B

- A. Source Quality: Obtain re-bonded recycled rubber impact sound isolation materials from a single manufacturer.

## **PART 3.0 - EXECUTION**

### 3.1 MANUFACTURER'S INSTRUCTIONS

- A. Compliance: Comply with manufacturer's product data, including product technical bulletins, product catalog installation instructions, and product carton instructions for installation.

### 3.2 EXAMINATION

- A. Site Verification of Conditions: Verify substrate conditions, which have been previously installed under other sections, are acceptable for product installation in accordance with manufacturer's instructions.

### 3.3 PREPARATION

- A. Surface Preparation: Surfaces shall be prepared in accordance with ANSI standards.

### 3.4 ERECTION/INSTALLATION/APPLICATION/CONSTRUCTION

- A. Re-bonded Recycled Rubber Impact Sound Isolation: Comply with the *ISOL*ayment QT technical manual for procedures and techniques for re-bonded recycled rubber Impact Sound Isolation installation.
- B. Related Products Installation: Refer to other sections listed in Related Sections paragraph herein for related products installation.
- C. Installation should not begin until all other trades are finished in the area.
- D. Areas to receive the re-bonded recycled rubber Impact Sound Isolation should be weather tight and maintained at a minimum uniform temperature of 65°F (18°C) for 48 hours before, during, and after the installation.

### 3.5 FIELD QUALITY REQUIREMENTS

- A. Manufacturer's Field Services: Upon Owner's request, provide manufacturer's field service consisting of product use recommendations in accordance with manufacturer's instructions.
- B. Field Tests should be performed by an independent acoustical laboratory accredited by the U.S. Department of Commerce, National Institute of Standards and Technology under the National Voluntary Laboratory Accreditation Program for the specified test procedure.

*ISOL*ayment QT-B



- C. The cost for all field acoustical testing, corrective work associated with the installation of the re-bonded recycled rubber Impact Sound Isolation and flooring to meet the minimum requirements, shall be borne by the flooring contractor(s).

### 3.6 CLEANING

- A. Remove temporary coverings and protection of adjacent work areas. Repair or replace damaged installed products. Clean installed products in accordance with manufacturer's instructions prior to Owner's acceptance. Remove construction debris from project site and legally dispose of debris.

### 3.7 PROTECTION

- A. Protection: Protect installed product and finish surfaces from damage during construction.

### 3.8 SCHEDULES

- A. Schedules: [Specify reference to applicable schedules].

**END OF SECTION**